

SALSIPUEDES SANITARY DISTRICT

Passing Criteria

For a Time of Sale Sewer Lateral Inspection to pass, the lateral shall have **no pipe structural grade 5 defects and no operational grade 4 or 5 defects, and the sum of all defect grades shall be less than thirteen (13).**
 Please note that structural defects are counted on a per pipe section basis (i.e. two separate cracks in a given pipe section will only be scored as "2" and not "4"), while operational defects are counted on a per incident basis.

Scoring System

Structural Defects

- Crack = 2
- Fracture = 3
- Broken/Hole/Deformed/Collapsed = 5
- Medium offset or Separation = 3
(≤ 1 pipe thickness)
- Large offset or Separation = 4
(> 1 pipe thickness)

Structural Defects (Continued)

- Sag - Shallow (< 30%) = 3
- Sag - Medium (30% - 50%) = 4
- Sag - Deep (> 50%) = 5

Operational Defects

- Roots - Fine (< 5%) = 1
- Roots - Medium (5% - 50%) = 3
- Roots - Ball (> 50%) = 4
- Deposits (< 20%) = 2
- Deposits (20%-30%) = 4
- Deposits (> 30%) = 5

Initial Inspection:

Distance (ft)	Defect	Grade	Remarks
1. _____	_____	_____	_____
2. _____	_____	_____	_____
3. _____	_____	_____	_____
4. _____	_____	_____	_____
5. _____	_____	_____	_____
6. _____	_____	_____	_____
7. _____	_____	_____	_____
8. _____	_____	_____	_____
Sum of Grades:		_____	<input type="checkbox"/> Pass <input type="checkbox"/> Fail

Post-correction Inspection (if needed):

Distance (ft)	Defect	Grade	Remarks
1. _____	_____	_____	_____
2. _____	_____	_____	_____
3. _____	_____	_____	_____
4. _____	_____	_____	_____
5. _____	_____	_____	_____
Sum of Grades:		_____	<input type="checkbox"/> Pass <input type="checkbox"/> Fail

Please give your professional opinion on the condition of the building sanitary sewer or sanitary sewer collection system: _____

DISTRICT USE ONLY:
 Date Received: _____
 Reviewed by: _____